



DEPARTMENT OF GENERAL SERVICES
PAUL N. PROTO
DIRECTOR

COMMONWEALTH OF VIRGINIA
COUNTY OF HENRICO

The complete addendum 2 will be mailed to plan holders.

ADDENDUM NO. 2

To: Prospective Bidders and Others Concerned
From: County of Henrico/Draper Aden Associates
Date: August 13, 2010
Re: Hermitage Farms Water System Improvements
DAA #R09296R, County Project No. 00812
Bid Request No. 10-8883-6CE

The following changes, corrections, deletions, clarifications, and/or additions constitute Addendum No. 2 to the project and are made to the Project Manual based on regulatory issues and questions received from potential bidders. All other general terms, conditions, specifications, and drawings shall remain the same. **Please acknowledge receipt of this Addendum No. 2, dated August 13, 2010 in the space provided on the Bid Form. Failure to acknowledge this addendum may result in your bid being declared non-responsive.**

CHANGE the Receive Date and Time August 17, 2010 @ 2:00 p.m. **TO** August 26, 2010 @ 2:00 p.m.

CHANGE the Open Date and Time August 18, 2010 @ 2:00 p.m. **TO** August 27, 2010 @ 2:00 p.m.

Additional changes, corrections, deletions, clarifications, and/or additions:

1. Specification Section 02713/3.15G/1. – The frequency of bacteriological sampling is changed from not exceeding 2,000 feet to not exceeding 1,200 feet to comply with the current AWWA Standards.

COUNTY OF HENRICO, VIRGINIA
GENERAL SERVICES/PURCHASING
CAROLYN L. EFFORD, CPPB
(804) 501-5688
eff@co.henrico.va.us

1590 E. PARHAM ROAD/P.O.BOX 90775/HENRICO, VIRGINIA 23273-0775
(804) 501-5660 FAX (804) 501-5693